



Precision Planning, Inc.
planners, engineers, architects & surveyors

ADDENDUM NO. 1
ISSUED MARCH 2, 2010

RE: WATER SYTEM IMPROVEMENTS PROJECT NO. E08-237
CITY OF LAWRENCEVILLE, GEORGIA
CONTRACT 2 - LAWRENCEVILLE WATER TREATMENT AND WATER DEPARTMENT FACILITIES

FROM: PRECISION PLANNING, INC. TO: PROSPECTIVE BIDDERS
(770) 338-8000

THIS ADDENDUM FORMS A PART OF THE CONTRACT DOCUMENTS AND CONSTRUCTION DRAWINGS AND MODIFIES THE ORIGINAL BIDDING DOCUMENTS FOR THE REFERENCED PROJECT DATED FEBRUARY 2010.

The following items of the contract documents are modified as part of this addendum:

- (1) **Advertisement for Bids:** Section 00030, the Bid Date is being changed from Wednesday, March 10 at 10:00 A.M. to Thursday, March 11 at 2:00 P.M.
- (2) All questions or requests for information shall be submitted in writing to the City's engineer, Precision Planning, Inc. in care of Jim Sunta, by fax at (770) 338-8094 or e-mail at 517js@ppi.us by no later than 10:00 A.M. on Monday, March 8. Any questions received after this date and time will not be accepted.
- (3) **Prestressed Circular Concrete Tank:** Section 03361, Sheets P6 and P7. The clearwell shall be designed to withstand hydrostatic pressures from groundwater at the 100-year flood elevation of 954.4 ft asl.

END OF ADDENDUM NO. 1